

VERIFICATION OF EMC COMPLIANCE

Applicant: WENZHOU LEEYEE ELECTRIC CO., LTD.
Address of applicant: NO.1 XINGYE ROAD, DAGANG, BEIBAIXIANG TOWN, YUEQING, ZHEJIANG 325603 CHINA
Manufacturer: WENZHOU LEEYEE ELECTRIC CO., LTD.
NO.1 XINGYE ROAD, DAGANG, BEIBAIXIANG TOWN, YUEQING, ZHEJIANG 325603 CHINA
Product Description: Surge Protective Device (Surge Protector)
Model No.: LY1, LY2, LY3, LY7, LY8, LY9, LY10, LY21, LY22, LY23, Series
Rating: In:5kA, 10kA, 15kA, 20kA, 25kA, 30kA, 40kA, 50kA, 60kA, 100kA (8/20 μ s);
Iimp:5kA, 6.25kA, 7kA, 12.5kA, 15kA, 25kA, 50kA (10/350 μ s);
Uc:120V, 140V, 240V, 275V, 320V, 385V, 400V, 420V, 440V, 690V AC; 6V, 12V, 30V, 60V, 500V, 600V, 800V, 1000V, 1200V, 1500V, 1800V DC;
Model:1P, 1+NPE, 2P, 3P, 3+NPE, 4P.

Sufficient samples of the product have been tested and found to be in conformity with Test Standard: EN IEC 61000-6-2:2019, EN IEC 61000-6-4:2019, EN IEC 61000-3-2:2019, EN 61000-3-3:2013+A1:2019

As shown in the Test Report Number(s): TEZJ21022529303
Date of issue: February 26th, 2021
Date of expiry: February 25th, 2026

Conclusion

This Verification of EMC Compliance has been granted to the applicant based on the results of the TCF, performed by Global Testing Services Co., Ltd. on the sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Directive 2014/30/EU. The CE mark as shown below can be used, Under the responsibility of the manufacturer, after completion of an EU Declaration of Conformity and compliance with all relevant EU Directives. The affixing of the CE marking presumes in addition that the conditions in annexes I, II and IV of the Directive are fulfilled.

Approved by: Hermann Weiher

For and on behalf of
Global Testing Services Co., Ltd



Global Testing Services Co., Ltd
E-mail: info@gts-lab.com <http://www.gts-lab.com>
Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China.